

**GOVERNMENT OF TELANGANA
ROADS & BUILDINGS DEPARTMENT**

From:
Sri B.Deshya, B.E.,
District Roads & Buildings Officer,
Mahabubnagar District.

✓ To,
The District Educational Officer,
Mahabubnagar District.

Lr. No. EE/R&B/DB/D3/MBNR/Structural Soundness/2026-27/761 Dt: .09.2026.

Sir,


Sub:- District Roads & Buildings Officer, Mahabubnagar – The Structural Soundness Certificate of International Delhi Public School, H.No. 10-4-32/K/4, Survey No.97, 98, Dwarakapuri Colony, Mahabubnagar District – Issued- Regarding.

- Ref:** 1) Application of Principal, International Delhi Public School, H.No. 10-4-32/K/4, Survey No.97, 98, Dwarakapuri Colony, Mahabubnagar District, Dated;- 27.08.2026.
2) Dy. E.E.(R&B), Sub-Division, Buildings, Mahabubnagar, Lr. No.DEE/R&B/BLDG/Soundness Certificate/2026-27, Dt: 9.09.2026.

&&&&&

The Structural and Soundness Certificate is hereby issued to International Delhi Public School, H.No.10-4-32/K/4, Survey No.97, 98, Dwarakapuri Colony, Mahabubnagar District, subject to conditions as appended in the certificate.

Encl: 1. Building Safety & Soundness certificate
2. Photos

Yours faithfully,

District Roads & Buildings Officer,
Mahabubnagar District.

Copy to the Dy. Executive Engineer(R&B), Sub-Division, Buildings, for information.

BUILDING SAFETY AND SOUNDNESS CERTIFICATE

- 1 Name of the Representative who Present at the time of inspection : **Mr.MD Younees, Correspondent**
- 2 Name of the School/College : **INTERNATIONAL DELHI PUBLIC SCHOOL**
- 3 Classification of College/School Buildings Specified in Certificate : **H.No:10-4-32/K/4,, Survey No: 97,98, Dwarakapuri Colony, Mahabubnagar District – 509001**
- 4 Period of which the certificate is issued : **1 Year from (08-09-2026 to 31-03-2027)**
- 5 Type of Structure : **R.C.C Structure**
- 6 Year of construction : **2025-26**
- 7 Number of floors : **Building- : G+3, Occupied: Ground+3 Floors**
- 8 Structural Designed for No. of floors : **Not provided by the School/Collage Management**
- 9 Nature of defects, if any
- | | | |
|--------------------------------|---|--|
| Q Foundation | : | Cannot specify because of it is substructure |
| R Basement | : | Nil |
| S Super structure | : | Nil |
| T Doors and windows | : | Nil |
| U Wood work wrought and put up | : | Nil |
| v Roof | : | Nil |
| w Flooring | : | Nil |
| x Miscellaneous (Cracks etc.) | : | Nil |
- 10 Any major defects noticed which will Render the building unsafe in any Manner: **Nil**
- 11 Whether maintenance work have been Done properly : **_____**
- 12 Whether the structure is sound or not For conducting classes : **Subject to compliance of the specific conditions As appended in the certificate.**


CERTIFICATE

Certified that the INTERNATIONAL DELHI PUBLIC SCHOOL as per the Photos at the site Occupied: G+3 Floor Only Building – Bearing House No: H.No:10-4-32/K/4,, Survey No: 97,98, Dwarakapuri colony in Mahabubnagar District was inspected on 08-09-2026 and physically observed the building and based on physical observation it is found to be run the school/college for the period one (01) Year from 08-09-2026 to 31-03-2027. Subject to the conditions that appended as below.


- 1) The live load on the building should not exceed more than accordance to 875(Part-2)-1987 for educational Building/Institutional Buildings (or) should not be more for which the building is structurally designed for live loads and Should not be more whichever is less of above two conditions which the building is structurally designed for live load
- 2) The building should not be extended vertically in future more than for which The building is designed structurally.
- 3) Any alteration and renovation of present building internally in future should be according to NBC norms/relevant IS codes and according to the guide lines of concerned education department.
- 4) All amenities and infrastructures of the building should be in according to NBC norms and concerned educational department norms.
- 5) The building is should be structurally design for School/College as per IS Standard (Part-2) -1987 loading i.e., educational/Institutions building.
- 6) Any deviations, in provided information by the school/college management regarding the building constructions and if any deviations of above specific Conditions, the issued certificate will be null and void.

Place: Mahabubnagar


Date: 08-09-2026



Assistant Executive Engineer
R&B Buildings Section
Mahabubnagar



Dy. Executive Engineer (R&B)
Buildings Sub-Division,
Mahabubnagar



District (R&B) Officer
(Executive Engineer)
Mahabubnagar